CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-1076:144 Page 1 of 2

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Kidde-Fenwal, Inc., 400 Main Street, Ashland, MA 01721

Contact: Terrill Garland (508) 881-2000 FAX (508) 881-1773

DESIGN: Control Unit Accessories. Refer to listee's data sheet for additional detailed system

description and operational considerations.

Models 70-407008-001 and 70-407018-001 normally-open contact input devices Models 70-407008-002 and 70-407018-002 normally-closed contact input devices Models 70-408004-001 and 70-408014-001 addressable relay output devices

Model 30-472001-000 remote trouble indicating panel

Model 30-220070-035 end-of-line resistor Model 74-200041-001 limiting resistor

Models 74-200012-001, 74-200012-002 and 74-200012-004 loop isolators

Models 89-100081-001 AIM (AnaLASER Interface Module) and 89-100083-001 IIM-2000

(Stand Alone)

Models 70-200200-001 and 70-200200-003 ASM (Addressable Signal Sounder Module), *73-100001-003 AAM (Addressable AlarmLine Module), 73-100003-001 AAM NEMA 4 Enclosure, 74-300000-502, 74-600000-005, 74-600000-515, 76-300000-502, and 76-600000-005 RDCM's

(Remote Display Control Modules), 74-300000-501 and 76-300000-501 RDM's (Remote

Display Modules)

Models 06-129827-001, 06-129827-002, 06-129827-003, 06-129828-001, and 06-129828-002

RDM/RDCM Enclosures

Models 74-300004-032 and 76-200004-032 ATM-L (Annunciator Driver Modules) Models 74-300005-032, and 76-200005-032 ATM-R (Relay Driver Modules)

Models 74-100017-001, 76-100010-001, 74-600000-014, and 74-600000-514 Battery Boxes. Models 74-600000-006, 74-600000-516 and 76-600000-006 Fiber-Optic Converter Cards

(OCC)

Models 06-220171-001 thru -007 Compensating Resistors.

Models 70-600000-001 and 70-600000-002 Remote Releasing Modules

Models 30-330002-001 and 84-330002-001 Addressable Manual Pull Stations. For indoor

use with Model SGB-32S back box or outdoor use with SGB-32C back box.

RATING: Electrical: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and

in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

*Rev. 02-04-2008 mt

APPROVAL:

Listed as control unit accessories for use with listee's separately listed model Fenwalnet 2000 and Fenwalnet 2000ML (CSFM Listing No. 7165-1076:141), Fenwalnet 6000 (CSFM Listing No. 7165-1076:183) or Pegasys and Pegasys ML (CSFM Listing No. 7165-1076:146) fire alarm control units. Refer to listee's Installation Instruction Manual for details.


Model 89-100083-001 IIM-2000 (Stand Alone) is intended for use with separately listed electrically compatible fire alarm control units.

Models 74-600000-006, 74-600000-516, 70-600000-001, 70-600000-002 and 06-220171-001 thru -007 are intended for use with separately listed Fenwalnet 6000 fire alarm control unit (CSFM Listing No. 7165-1076:184).

Model 76-600000-006, 70-600000-001, 70-600000-002 and 06-220171-001 thru -007 are intended for use with separately listed Aries fire alarm control unit (CSFM Listing No. 7165-1076:183).

Model 30-330002-001 is intended for use with separately listed Models Fenwalnet 2000 (CSFM Listing No. 7165-1076:141) and Fenwalnet 6000 (CSFM Listing No. 7165-1076:184) fire alarm control units.

Model 84-330002-001 is intended for use with separately listed Models Kidde PEGAsys (CSFM Listing No. 7165-1076:146) and ARIES (CSFM Listing No. 7165-1076:183) fire alarm control units.





This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 4, 2008 Listing Expires June 30, 2009

Authorized By: **BEN HO**, Chief

Fire Engineering Division